



**National Trust for
Historic Preservation**
Save the past. Enrich the future.

Addendum No. 1

PROJECT: NINA SIMONE CHILDHOOD HOME EXTERIOR & INTERIOR REHABILITATION RFP 2024-6

DATE: MARCH 19, 2024

RE: ADDENDUM NO. 1 TO REQUEST FOR PROPOSALS

TO: ALL BIDDERS

This addendum forms a part of the Contract Documents and modifies the original Bidding Documents and shall be included in the relevant scopes of work and bids submitted. It is the bidder's responsibility to determine if their work is affected by this addendum. Failure to acknowledge receipt of this Addendum on bid submission may subject the Bidder to disqualification.

The Following is AMENDED:

GENERAL NOTES AND CLARIFICATIONS: None

DRAWINGS: None

SPECIFICATIONS: Answer to Question

END OF ADDENDUM NO. 1

Answer to Question

Question: Is there a proposed location for the well head for the geothermal heat pump system?

Answer: The geothermal bore hole will be in the front yard in the approximate location where shown on the drawings. The piping will be 3 to 4 feet below grade. There will not be a visible well head after the pipe is installed.